

COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

THE APPLICATION OF SOUTH SHORE WATER)
COMPANY FOR A DEVIATION FROM THE)
REQUIREMENTS OF 807 KAR 5:066, SECTION) CASE NO. 10263
5(4) REGARDING WATER STORAGE)

O R D E R

On July 20, 1988, the Commission granted South Shore Water Works Company ("South Shore") a limited deviation from 807 KAR 5:066, Section 5(4), which requires a water utility to provide water storage to insure one day's supply of its average daily water usage. The Commission found that South Shore's average daily usage would be 692,262 gallons.

On July 25, 1988, South Shore requested that the Commission reduce the average daily usage amount to 463,632 gallons. As no hearing has been held in this proceeding, the Commission shall consider South Shore's request as a motion for reconsideration of its final Order.

After review of the record in this proceeding, and the additional information filed by South Shore, the Commission finds that South Shore's motion for reconsideration should be granted, and a public hearing should be held to enable South Shore to present its evidence.

IT IS THEREFORE ORDERED that:

1. South Shore's motion for reconsideration be and it hereby is granted.

2. A public hearing on South Shore's water storage requirements be and it hereby is scheduled on September 28, 1988 beginning at 1:30 p.m., Eastern Daylight Time in Hearing Room #1 at the Commission's offices at Frankfort, Kentucky.

3. The Commission's final Order in this proceeding be and hereby is reaffirmed in all other respects.

Done at Frankfort, Kentucky, this 15th day of August, 1988.

PUBLIC SERVICE COMMISSION

Richard D. Weman Jr.
Chairman

Robert M. Davis
Vice Chairman

Spencer M. Williams
Commissioner

ATTEST:

Executive Director